



FIRE TEST CERTIFICATION TO ISO 10497 API 6FA AND BS 6755

Project: **Buracco**
Rue de Chez l'Ecuyer ZA le Pré Long- BP 6
F-71300 Montceau-les-Mines FRANCE

Client: **CEWAC**
Rue Bois Saint-Jean, 8
B-4102 Ougrée BELGIUM

Office: **ANTWERP**

Clients Order Number: **CEWAC ref: PV n°170419E03**

Date: **20/04/2017**

Order Status: **Complete**

Inspection Dates

First: **19/04/2017**

Final: **19/04/2017**

This certificate is issued to the company mentioned here above to certify that the undersigned Surveyor to this Society did at their request attend CEWAC asbl, rue Bois Saint-Jean 8, B-4102 OUGREE-SERAING, BELGIUM, on the 19/04/2017 in order to witness a fire test on the following material:

CHECK VALVE.
TYPE DAUPHIN.
NPS 4 (DN100) CLASS150.
BODY MATERIAL: A105 + APPORT
SEAT MATERIAL: HARD FACED
GENERAL ASSEMBLY DRAWINGS: NOM 1735/A.

Fire test has been performed in our presence by CEWAC asbl, according NBN EN ISO 10497, 2010 / BS 6755 : part 2 : 1987 / API 6FA, 1999 and is documented by test report PV n°170419E03 issued by CEWAC.

The described valve has been submitted to a hydrostatic test at 27 bar followed by a fire test for a period of 30 minutes.

During the test period, the average calorimeters temperature has been found at minimum 650°C.

All relevant information, parameters and results are recorded in above mentioned test report issued by CEWAC asbl and endorsed by undersigned Surveyor for acceptance.

CONCLUSIONS:

ALL RESULTS HAVE BEEN FOUND ACCEPTABLE TO NBN EN ISO 10497 3rd edition 15/02/2010, BS 6755 : part 2 : 1987 and API 6FA 3rd edition 04/1999.

As per specification, the range of valves qualified is:

SIZE: NPS 4; 5; 6; 8 (DN 100; 125; 150; 200)

PRESSURE RATING: CLASS 150; 300 (PN 10; 16; 25; 40)

BODY MATERIAL: Ferritic

SEAT MATERIAL: metal



Surveyor to Lloyd's Register EMEA
A subsidiary of Lloyd's Register Group Limited

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.